

filename : TRIDENT-115-LEDLITE-OPAL.ldt
 meas. number : 3252
 luminaire number : TRIDENT-115-LEDLITE-OPAL
 date / operator : 29-09-2020

luminaire documentation

**default lamp type(s)**

no of lamps	lamp type	luminaire lumens	input wattage
1	LED MODULE	3605 lm (mains) 480 lm (3hr. emergency)	29.8 W

dimensions

luminaire		luminous area	
length	: 1530 mm	length	: 1320 mm
width	: 80 mm	width	: 70 mm
height	: 80 mm	height	: 30 mm

coordinate system

no of planes	: 7	samples / plane	: 37
first c-plane	: 0.0 °	first gamma-angle	: 0.0 °
step angle	: 15.0 °	step angle	: 5.0 °
last c-plane	: 90.0 °	last gamma-angle	: 180.0 °
symmetrics	: symmetry to C0 / C90		


performance

light output ratio : 100.0 %
 DFF : 91.0 %
 UFF : 9.0 %


classification

LiTG / DIN : A31
 UTE : 0.91G+0.09T
 CIE : 41 70 89 91 100
 BZ : 5 5 5 5 5 5 5 5

Ambient Temperature : 25 degC
 Input Voltage : 240 V
 Circuit Watts : 29.8W
 Amps (running) : 0.129A
 V.A. : 31.04 VA
 Power Factor : 0.96
 CCT : 4005K (measured); 4000K (declared)
 CRI (Ra) : 84
 S/P Ratio : 1.7
 Luminaire Lumens : 3605 LLm (mains)
 : 480 Llm (3hr.emergency)
 Output Current DC : 680mA
 Output Voltage DC : 35.8V
 Output Power : 24.34W
 Luminaire Lm/circ.Watt : 121 LLm/circ.Watt
 Driver Efficiency : 82%
 Driver Details : POWERLAND PLD030-1SCH83



Measurements made are in absolute units. The luminaire is treated as if it was a lamp as it is not possible to measure each LED separately - hence an LOR of 100%
 The Light output ratio in real terms would be less than 100%. If it was possible to compare real LED lumens with the total output from the luminaire we could obtain an actual LOR
 This also means that the total lumens emitted from the LED's would be greater than the Luminaire Lumens measured. In reality the LED lumens would approximate to this value divided by the actual Light Output.



	C 0.0	C 15.0	C 30.0	C 45.0	C 60.0	C 75.0	C 90.0
0.0°	270.40	270.40	270.40	270.40	270.40	270.40	270.40
5.0°	269.30	269.30	269.30	269.40	269.50	269.30	269.10
10.0°	266.30	266.50	266.60	266.20	265.80	265.50	265.10
15.0°	261.60	261.70	261.70	260.90	260.10	259.70	259.20
20.0°	255.50	255.30	255.10	253.50	252.00	251.00	250.00
25.0°	247.90	247.00	246.10	243.80	241.50	240.00	238.50
30.0°	238.30	237.20	236.20	232.80	229.40	227.50	225.60
35.0°	228.70	226.60	224.60	219.70	214.90	212.60	210.40
40.0°	216.50	213.80	211.20	206.00	200.90	197.30	193.80
45.0°	204.00	200.70	197.30	190.70	184.20	180.10	175.90
50.0°	188.60	185.50	182.50	173.90	165.30	161.00	156.70
55.0°	174.40	170.70	167.00	157.00	147.00	142.70	138.40
60.0°	159.20	155.10	151.00	140.00	128.80	122.10	115.40
65.0°	143.60	139.40	135.20	122.30	109.40	101.60	93.70
70.0°	129.00	124.00	119.00	105.00	91.00	81.40	71.70
75.0°	113.80	108.70	103.60	88.90	74.20	62.10	49.90
80.0°	99.40	94.10	88.90	74.10	59.20	44.60	30.10
85.0°	85.60	80.40	75.20	59.70	44.10	29.30	14.40
90.0°	72.80	67.90	62.90	47.90	32.90	20.10	7.10
95.0°	61.00	56.80	52.60	38.60	24.80	15.30	5.80
100.0°	51.50	47.10	42.70	30.60	18.50	11.80	5.10
105.0°	42.50	38.40	34.40	24.00	13.40	8.90	4.40
110.0°	34.10	30.50	27.00	18.20	9.40	6.60	3.80
115.0°	27.20	24.10	20.90	13.70	6.40	4.90	3.50
120.0°	20.90	18.30	15.60	10.10	4.60	2.30	0.00
125.0°	15.50	13.10	10.70	7.10	3.50	1.70	0.00
130.0°	10.90	8.90	7.00	3.50	0.00	0.00	0.00
135.0°	7.00	6.00	5.00	2.50	0.00	0.00	0.00
140.0°	4.40	4.10	3.70	1.80	0.00	0.00	0.00
145.0°	3.50	3.40	3.30	1.70	0.00	0.00	0.00
150.0°	3.30	1.70	0.00	0.00	0.00	0.00	0.00
155.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
160.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
165.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
170.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
175.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
180.0°	0.00	0.00	0.00	0.00	0.00	0.00	0.00
	cd / klm						

glare rating according to UGR											
ρ -ceiling		70	70	50	50	30	70	70	50	50	30
ρ -walls		50	30	50	30	30	50	30	50	30	30
ρ -workplane		20	20	20	20	20	20	20	20	20	20
room dimensions X Y		viewed crosswise					viewed endwise				
2H	2H	19.5	21.0	19.9	21.3	21.7	19.2	20.6	19.6	21.0	21.4
	3H	20.7	21.8	21.1	22.1	22.4	20.0	21.1	20.4	21.4	21.7
	4H	21.7	22.7	22.0	23.0	23.4	20.7	21.7	21.0	22.0	22.4
	6H	22.6	23.6	23.0	23.9	24.3	21.1	22.1	21.5	22.4	22.8
	8H	23.1	24.0	23.5	24.4	24.7	21.3	22.3	21.7	22.6	23.0
	12H	23.5	24.5	23.9	24.8	25.2	21.5	22.4	21.9	22.8	23.2
4H	2H	19.4	20.5	19.8	20.8	21.1	19.2	20.2	19.5	20.5	20.9
	3H	21.7	22.6	22.1	23.0	23.4	21.0	21.9	21.4	22.3	22.7
	4H	22.8	23.8	23.3	24.2	24.6	21.8	22.8	22.3	23.2	23.6
	6H	23.7	24.5	24.2	24.9	25.4	22.3	23.1	22.7	23.5	23.9
	8H	24.3	25.0	24.7	25.4	25.9	22.5	23.2	23.0	23.7	24.1
	12H	24.9	25.6	25.4	26.0	26.5	22.8	23.5	23.3	23.9	24.4
8H	4H	23.0	23.7	23.5	24.1	24.6	22.1	22.8	22.6	23.3	23.7
	6H	24.5	25.1	25.0	25.6	26.1	23.1	23.8	23.6	24.3	24.8
	8H	25.2	25.8	25.7	26.3	26.9	23.5	24.2	24.1	24.7	25.2
	12H	25.8	26.3	26.3	26.8	27.4	23.7	24.3	24.3	24.8	25.3
12H	4H	23.1	23.8	23.6	24.2	24.8	22.3	23.0	22.8	23.4	24.0
	6H	24.6	25.2	25.1	25.7	26.3	23.4	24.0	23.9	24.5	25.0
	8H	25.3	25.8	25.8	26.3	26.9	23.7	24.2	24.2	24.7	25.3
variation of observer position											
S =	1.0H	+0.1/		-0.1		+0.1/		-0.1			
	1.5H	+0.2/		-0.2		+0.2/		-0.2			
	2.0H	+0.2/		-0.3		+0.3/		-0.5			
standard-table		BK09					BK07				
correction for luminaire		9.4					7.3				
correct glare indices for a total flux of 3605lm											





Table of Luminance

gamma	C 0	C 90	C 180	C 270
45°	7879.1	9489.7	7879.1	9489.7
50°	7577.3	9260.4	7577.3	9260.4
55°	7358.8	9118.1	7358.8	9118.1
60°	7129.9	8663.7	7129.9	8663.7
65°	6907.9	8248.2	6907.9	8248.2
70°	6758.0	7698.3	6758.0	7698.3
75°	6599.3	6933.9	6599.3	6933.9
80°	6510.1	5990.7	6510.1	5990.7
85°	6496.2	5116.9	6496.2	5116.9

all values in cd/m²

utilization factors / TM5											
reflection			room index								
C	W	F	0.75	1.0	1.25	1.5	2.0	2.5	3.0	4.0	5.0
70	50	20	53	61	68	73	80	85	89	94	97
70	30	20	45	53	60	66	74	79	83	89	93
70	10	20	40	47	54	60	68	74	78	84	89
50	50	20	51	58	65	69	76	80	84	88	91
50	30	20	44	51	58	63	70	75	79	84	87
50	10	20	39	46	53	58	65	71	75	80	84
30	50	20	48	55	61	66	72	76	79	83	86
30	30	20	42	49	56	60	67	71	75	80	83
30	10	20	38	44	51	56	63	68	71	77	80
0	0	0	35	41	47	51	58	62	66	70	73
BZ-class			5	5	5	5	5	5	5	5	5
SHRnom : 1.50						SHRmax : 1.681					

MAINS MODE



EMERGENCY MODE

