

INSTALLATION INSTRUCTIONS



OMEGA LTM-1.5W-SM




Important Safety

1. Before installation or maintenance, ensure that the mains supply to the luminaire is switched off and circuit supply fuses are removed or the circuit breaker is turned off.
2. It is recommended that only a qualified electrical contractor carries out the installation of this luminaire and that the luminaire is installed in compliance with the current edition of the IEE wiring Regulations.
3. The person carrying out the installation is to check and verify that the total load on the circuit, including that of this luminaire does not exceed the rating of the circuit cable, fuse or circuit breaker.
4. Where applicable, careful consideration should be taken during installation to ensure that all fixings and/or suspensions are of a suitable size for the luminaire being installed.


Installation:

1: Isolate mains



Ensure that the mains supply is switched off before installing, maintaining or servicing the emergency luminaire.


2: Remove front cover



Use screwdriver to press the small hole on the side, then lift up the mounting base.

Click!

3: Install base




Drill where indicated and use wall plugs and screws*
Remove lid on the side if connected to 20mm conduit

0.5Nm
3-4mm

*supplied screws and wall plugs are suitable for masonry only.
Please purchase alternative fixings if required.


4: Cable size and strip length



Blue N
Brown L (Permanent)

0.75 - 1.5mm² 8+1mm

5: Connect mains




- This product is classified as Class II. Earth connection not required
- Secure mains cable by using cable clip and screws supplied

6: Complete labels

Part No.:
Input voltage: 220-240V AC 50Hz


X	0	180
---	---	-----

Installation date: __/__/__




- Enter installation date on battery label
- Enter the appropriate code on the luminaire label

7: Re-attach front cover



Click!

8: Restore mains supply



Warning

- Failure to comply with these instructions may result in irreparable damage to the emergency control gear.
- This product must not be modified in any way as this will negate any Safety approvals, and may render the product inoperable or unsafe. The product must be installed in accordance with the instructions.





Telephone: +44 (0)1704 512000
Email: info@morganhope.com www.morganhope.com